



Molded-plastic installation enclosure with emergency stop rotary operating mechanism with metric cable gland No UL/CSA approval

product designation		ISO installation housing with EMERGENCY OFF	
design of the product		Installation	
General technical data			
product function EMERGENCY OFF function		Yes	
protection class IP of the enclosure		IP55	
Substance Prohibittance (Date)		07/01/2006	
Enclosure			
material of the enclosure		plastic	
Installation/ mounting/ dimensions			
height		175 mm	
width		105 mm	
depth		108 mm	
Approvals Certificates			
General Product Approval		Declaration of Conformity	Test Certificates
			Marine / Shipping

[Confirmation](#)



[Special Test Certificate](#)



Marine / Shipping

other

Railway



[Miscellaneous](#)

[Confirmation](#)



[Special Test Certificate](#)

Further information

Siemens has decided to exit the Russian market (see here).

<https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business>

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

<https://support.industry.siemens.com/cs/ww/en/view/109813875>

Information- and Downloadcenter (Catalogs, Brochures,...)

<https://www.siemens.com/ic10>

Industry Mall (Online ordering system)


<https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RV1923-2GA00>

Cax online generator

<https://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RV1923-2GA00>

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

<https://support.industry.siemens.com/cs/ww/en/ps/3RV1923-2GA00>



last modified:

12/23/2020 