SIEMENS

Data sheet

3SE5212-0AC05



Empty enclosure for position switch Metal enclosure according to EN 50047, 31 mm M20 x 1.5 with cover Color turquoise and plunger

product designation	empty enclosure EN 50047, cover turquoise				
General technical data					
product function positive opening	Yes				
insulation voltage rated value	400 V				
protection class IP	IP66/IP67				
shock resistance					
 according to IEC 60068-2-27 	30g / 11 ms				
vibration resistance					
 according to IEC 60068-2-6 	0.35 mm/5g				
material of the enclosure of the switch head	metal				
reference code according to IEC 81346-2	U				
repeat accuracy	0.05 mm				
Substance Prohibitance (Date)	07/01/2006				
minimum actuating force in directions of actuation	20 N				
length of the sensor	75.7 mm				
width of the sensor	31 mm				
Ambient conditions					
ambient temperature					
 during operation 	-25 +85 °C				
during storage	-40 +90 °C				
explosion protection category for dust	none				
Enclosure					
design of the housing	block, narrow				
material of the enclosure	metal				
coating of the enclosure	cathodic dip coating				
design of the housing according to standard	Yes				
Drive Head					
design of the actuating element	Rounded plunger, plastic plunger				
standard-compliant actuator head	EN 50047, design B				
shape of the switch head	rounded				
design of the switching function	Positive opening with appropriate positive opening actuator head and switching element				
cable entry type	1x (M20 x 1.5)				
Installation/ mounting/ dimensions					
mounting position	any				
fastening method	screw fixing				
Connections/ Terminals					
type of electrical connection	screw-type terminals				
design of the interface for safety-related communication	without				
Communication/ Protocol					

design of the interface			without				
Certificates/ approvals							
General Product Approval							
	<u>Confirmation</u>			KC	EHC		
Functional Safety/Safety of Ma- chinery	Declaration of Conformity		Test Certificates	other			
Type Examination Cer- tificate	UK CA	CE EG-Konf.	Type Test Certific- ates/Test Report	<u>Confirmation</u>			

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SE5212-0AC05

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3SE5212-0AC05

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3SE5212-0AC05

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3SE5212-0AC05&lang=en







last modified:

1/26/2022 🖸