
SIEMENS

Data sheet

3SU1851-0AA00-0AA2



Enclosure for command devices, 22 mm, round, Enclosure material metal, Enclosure top part yellow, 1 control point, without equipment, Control point in center, floor mounting, 1xM20 each on top and bottom

product brand name	SIRIUS ACT			
product designation	Enclosures			
product type designation	3SU1			
Enclosure				
design of the housing	Command point in center			
shape of the enclosure front	Square			
material of the enclosure	metal			
number of command points	1			
product component protective collar	No			
color of the enclosure top part fastening method of the enclosure	yellow Vertical / horizontal			
General technical data	Ventical / honzontal	_		
protection class IP				
·	IP66, IP67, IP69(IP69K)			
degree of protection NEMA rating shock resistance for railway applications according to EN 61373	1, 2, 3, 3R, 4, 4X, 12, 13			
	Category 1, Class B			
vibration resistance for railway applications according to EN 61373	Category 1, Class B			
Substance Prohibitance (Date)	10/01/2014			
cable entry type	Without			
Connections/ Terminals				
type of electrical connection on enclosure	Cable routing above and below, both 1 x M20			
tightening torque of fixing screws in the enclosure cover	1.5 1.7 N·m			
Ambient conditions				
ambient temperature				
during operation	-25 +70 °C			
during storage	-40 +80 °C			
environmental category during operation according to IEC 60721	3M6, 3S2, 3B2, 3C3, 3K6 (with relative air humidity of 10 95%, no condensation in operation permitted for all devices behind front panel)			
Installation/ mounting/ dimensions				
fastening method of modules and accessories	Floor mounting			
height	89.4 mm			
width	85 mm			
depth	64 mm			
mounting diameter	22.3 mm			
positive tolerance of installation diameter	0.4 mm			
Certificates/ approvals				
General Product Approval		Declaration of Con- formity		

	<u>Confirmation</u>	(UL)	UDE VDE	EHC	CE EG-Konf.	
Declaration of Con- formity	Test Certificates		Marine / Shipping			
UK CA	<u>Special Test Certific-</u> <u>ate</u>	<u>Type Test Certific-</u> ates/Test Report	ABS	Llovds Register us	PRS	
Marine / Shipping	other	Environment				
RINA	<u>Confirmation</u>	Environmental Con- firmations				
Further information						
Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business Siemens is working on the renewal of the current EAC certificates. Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an						
	ther than the sanctioned B				,	
https://support.industry.siemens.com/cs/ww/en/view/109813875						
Information- and Dow https://www.siemens.co	nloadcenter (Catalogs, E om/ic10	Brochures,…)				
Industry Mall (Online		alog/product2mlfb=25144				


https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SU1851-0AA00-0AA2

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3SU1851-0AA00-0AA2

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3SU1851-0AA00-0AA2

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3SU1851-0AA00-0AA2&lang=en



last modified:

1/26/2022 🖸