## **SIEMENS**

## **Data sheet**

## 3SU1854-0AA00-0AB1

	Enclosure for command devices, 22 mm, round, Enclosure enclosure top part gray, 4 control points, without equipmer		
	floor mounting, 1xM25 each on top and bottom		
product brand name	SIRIUS ACT		
product designation	Enclosures		
product type designation	3SU1		
Enclosure			
design of the housing	with recess for label		
shape of the enclosure front	rectangular		
material of the enclosure	metal		
number of command points	4		
product component protective collar	No		
color of the enclosure top part	grey		
fastening method of the enclosure	Vertical / horizontal		
General technical data			
protection class IP	IP66, IP67, IP69(IP69K)		
degree of protection NEMA rating	1, 2, 3, 3R, 4, 4X, 12, 13		
shock resistance for railway applications according to EN 61373	Category 1, Class B		
vibration resistance for railway applications according to EN 61373	Category 1, Class B		
Substance Prohibitance (Date)	10/01/2014		
cable entry type	Without		
Connections/ Terminals			
type of electrical connection on enclosure	Cable routing above and below, both 1 x M25		
tightening torque of fixing screws in the enclosure cover	1.5 1.7 N·m		
Ambient conditions			
ambient temperature			
<ul> <li>during operation</li> </ul>	-25 +70 °C		
during storage	-40 +80 °C		
environmental category during operation according to IEC 60721	3M6, 3S2, 3B2, 3C3, 3K6 (with relative air humidity of 10 95%, no condensation in operation permitted for all devices behind front panel)		
Installation/ mounting/ dimensions			
fastening method of modules and accessories	Floor mounting		
height	199 mm		
width	85 mm		
depth	64 mm		
mounting diameter	22.3 mm		
positive tolerance of installation diameter	0.4 mm		
Certificates/ approvals			
General Product Approval		Declaration of Conformity	



Confirmation









**Declaration of Conformity** 

**Test Certificates** 

Marine / Shipping



Special Test Certificate

Type Test Certificates/Test Report







Marine / Shipping

other

**Environment** 



Confirmation

**Environmental Con**firmations

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SU1854-0AA00-0AB1

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3SU1854-0AA00-0AB1

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3SU1854-0AA00-0AB1

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3SU1854-0AA00-0AB1&lang=en

ast modified:	1/26/2022	ڄم	ı
ast mounica.	1/20/2022	$\sim$	