

## Cable Management Numbers-Up Style Sample Rack

Part Number:R2P26

**INSTRUCTIONS CM463** 







Apply Antioxidant Paste to painted surfaces that the 3/8 paint piercing washers will come in contact with. Install top channel to upright channels using (4) 3/8x1" bolts (4) 3/8" nuts and (8) 3/8" paint piercing washers (see figure below). Finger tighten only.

Apply Antioxidant Paste to painted surfaces that the 3/8 paint piercing washers will come in contact with. Install the base angles to the vertical upright channels using (8) 3/8x1" bolts (8) 3/8" nuts and (16) 3/8" paint piercing washers (see figure to left) per angle. Finger tighten only.

Fasten handle to top channel of rack using supplied hardware and completely tighten (see figure below).

Rack holes for mounting sample managers

Stand rack upright. Square the upright channels with the base using a carpenter square. Completely tighten all bolts to at least 14 ft.-lbs(19.0 N-m).



www.panduit.com/resources/install\_maintain.asp

www.panduit.com

Fax: (708) 444-6993

Page 1 of 1